

Engineering has reviewed the TRC submittal for the Car Star Expansion project and offers the following comments:

1. The project proposes less than or equal to 10,000 square feet of impervious and greater than 2,500 square feet of impervious. This qualifies the project as a drainage plan and will require a submittal directly to Engineering that includes: a \$400 drainage plan review fee, stormwater permit application (Form SWP 2.2), revised plans, and digital copies of all documents in the submittal.