

Airlie at Wrightsville Sound Revision 2

Planning Review – 6/28/18

Brian Chambers, brian.chambers@wilmingtonnc.gov, 910.342.2782

- Bring impervious coverage amount down to 57.5%. If you allocate 10,185 coverage for both lots 38 and 39 this will bring the impervious down to the amount needed for the proposed 65 points.
- We will need to confirm impervious coverage and lot coverage with Engineering for compliance with stormwater permit.
- No further comments from planning.