

Bearman CPA Office Revision 1

Planning Review 3/23/20

Brian Chambers, brian.chambers@wilmingtonnc.gov, 910.342.2782

Planning Comments:

- All parking spaces need to be accessible (not behind fence).
- Clear pedestrian path to the public sidewalk needs to be maintained. Parking is now in the area that was to serve this purpose.