

**The Collection at Independence**

*TRC Planning Review 6/6/19*

Brian Chambers, [brian.chambers@wilmingtonnc.gov](mailto:brian.chambers@wilmingtonnc.gov)

- Provide foundation planting calculation for south side of Building G1.
- Provide area (sf) of required landscape islands at end of each parking row. Minimum of 216 square feet.