

To: Branch Smith, PE
From: Pat O'Mahony, Associate Planner; 910-341-0189
CC: File;
Date: 8/16/2021
Re: College Acres Parking Lot TRC Rev. 2

The following is a list of comments for review from planning regarding the project. Please provide your corrections as listed below. A staff summary of comments:

Staff	Department	Notes
Pat O'Mahony	Planning, Plan Review	No further comments
Richard Christensen	Engineering	Comments attached
Chris Walker	Fire	No further comments
Mitesh Baxi	Traffic Engineering	No further comments
Bill McDow	Transportation	No further comments

Pat O'Mahony- Planning

- No further comments.

Engineering has reviewed the plans for the College Acres Parking Lot project submitted August 3, 2021 for TRC review and have the following comments:

Design Documents

1. C-2.0:
 - a. Impervious Data: Proposed impervious does not match the application.
 - b. Add a callout for the header curb between the PC and conventional asphalt to ensure it gets installed.
2. No further comments from Engineering. Revised plans do not need to be resubmitted for Engineering review.