

*Project Name: RIVERLIGHTS CONVENTIONAL PH V & VI*  
*Formal TRC #4 Date: 06.23.2021*  
*Reviewer Name: Mitesh Baxi*  
*Reviewer Department/Division: PDT/Traffic Engineering*

---

**SIGNAGE AND PAVEMENT [MUTCD]:**

1. Please show all the applicable warning signage pertaining to the roundabout approach on River Rd. Plans show Pedestrian crossing warning sign, but it is missing diagonal downward pointing arrow plaque (W16-7P) [MUTCD].
2. Signage keynote 3: A Yield here to pedestrian (R1-5a) signs are not required for the intersection at Trisail Terrace and Shoal Way and shall not be installed.

Please let me know if you have any questions or if I can be of further assistance.