

Project Name: **RIVERLIGHTS MX2A TOWNHOMES**
Formal TRC #4 Date: **04.20.2022**
Reviewer Name: **Mitesh Baxi**
Reviewer Department/Division: **PDT/Traffic Engineering**

SIGNAGE AND PAVEMENT MARKING PLAN: [[Sign Specification and Installation Guide](#)] [[Required Minimum Sign and Plaque Sizes](#)] [[MUTCD](#)]

1. A Pedestrian Crossing (W11-2) warning sign post-mounted with a diagonal downward pointing arrow (W16-7P) plaque are required to be installed on both the sides of the crosswalk at the connection of existing and proposed section of Watercraft Ferry Ave.

STREET LIGHTING [[City of Wilmington Street Lighting Policy](#)]:

1. Provide the details for the type and number of streetlights proposed for this project on the plans.
2. One streetlight will be required at the end of Watercraft Ferry to achieve minimum nonstandard streetlighting levels.

Please let me know if you have any questions or if I can be of further assistance.