

Home 2 Suites by Hilton

Brian Chambers, brian.chambers@wilmingtonnc.gov, 910.342.2782

TRC Planning Review 3/19/19

- Lot recombination and street closure will need to be recorded prior to full construction release.
Leaving this note as a reminder.
- Landscape island is needed within parking row along eastern boundary. No space can be more than 120 feet from a landscape island.
- Landscape island trees are needed in islands on either end of parking row closest to Market Street.
- Protected trees cannot be removed from streetyard. There are a couple protected trees on Eastwood Service Rd frontage.
- Mitigation table on landscape plan does not match tree removal table submitted with tree removal permit. Please reconcile/correct.
- Protected trees removed for essential site improvements do not require mitigation.