



To: Charles Cazier, PE
From: Nicole Smith, Associate Planner; 910-341-1611
CC: File;
Date: 12/10/2019
Re: Howard RV Center

The following is a list of comments for review from planning regarding the project. Please provide your corrections as listed below. Additional review will be required once all the needed documents have been provided. Items or documents not provided on initial submission will be subject to further review. Please contact me for any further questions.

Tree Removal Comments:

• Comments will be provided once Aaron Reese verifies the updated tree survey.

Landscape Plan to Include:

- Please add the required planting sizes to the legend for consistency and to ensure compliance with Sec. 18-448.
- Please add callouts to the Landscape Plan for each proposed planting. It is difficult to read in some areas.
- Please update the calculations for the 15 trees/acre. 5.14x15=77 required, not 71 trees. Update the existing preserved trees to satisfy the requirement.