

**To:** Renee Pfeifer, ASLA, PLA  
**From:** Nicole Smith , Associate Planner; 910-341-1611  
**CC:** File;  
**Date:** 1/14/2020  
**Re:** Maides Park Gymnasium Addition

---

The following is a list of comments for review from planning regarding the project. Please provide your corrections as listed below. Additional review will be required once all the needed documents have been provided. Items or documents not provided on initial submission will be subject to further review. Please contact me for any further questions.

Landscape Plan to Include:

- Review proposed tree removal tables. Comments updated with modified submittal:
  - Tree Credits modifications:
    - Total DBH of all Trees/6=61, not 63 per Sec. 18-448, Table I. 6-11” caliper trees calculation is incorrect. 44” caliper total in this category.
- Update streetyard calculations. 3 existing trees in streetyard. 2 proposed. I additional tree required per code. 2 existing trees in the islands can’t count twice.
- Trees preserved calculations do not match on sheets C102 and C601.