

**To:** Daniel Suarez, Kimley-Horn  
**From:** Pat O'Mahony, Associate Planner; 910-341-xxxx  
**CC:** File;  
**Date:** 9/26/2019  
**Re:** Mayfaire Self Development Plan Rev. 2

---

The following is a list of comments for review from planning regarding the project. Please provide your corrections as listed below. Additional review will be required once all the needed documents have been provided. Items or documents not provided on initial submission will be subject to further review. Please contact me for any further questions.

Site Plan Comments:

- Sec. 18-504: Show compliance with screening of dumpsters with living and non-living material.
  - Screening shall be a minimum of 6 feet in height along the front or corner side of any lot and 8 feet in height along any side or rear property line.