

Renaissance II Landscape Plan Revision

TRC Planning Review 8/2/18

Brian Chambers, 910.342.2782, brian.chambers@wilmingtonnc.gov

Planning Comments:

- Remove incorrect shading calculation from site data table (i.e. 14%).
- The Live Oaks in the interior islands would be 707 sq ft. Please adjust number/calculations accordingly.
- Delineate maximum width of streetyard on Ashes Drive, difficult to see with line work.