

To: Garry Pape, GSP Engineering
From: Pat O'Mahony, Associate Planner; 910-341-0189
CC: File;
Date: 10/28/2019
Re: Triangle Auto Sales Review 2

The following is a list of comments for review from planning regarding the project. Please provide your corrections as listed below. Additional review will be required once all the needed documents have been provided. Items or documents not provided on initial submission will be subject to further review. Please contact me for any further questions.

Site Plan Comments:

- A tree preservation/removal permit is required
- Provide a pedestrian connection from the proposed sidewalk to the building entrance.
- A cross access connection is recommended between adjacent properties.