

Woodlands Tract 3B Revision 2

TRC Planning Review 7/17/19

Brian Chambers, brian.chambers@wilmingtonnc.gov, 910.342.2782

Comments

- Loblolly Pine is significant at 32" not 24". The 29" Loblolly is not significant.
- Be sure tree mitigation table is consistent with the approved tree removal plan (C0.4-C0.7).
- Need street trees on portion of Chastain Drive that is included in this approval.