



**Public Services**  
Engineering  
212 Operations Center Drive  
Wilmington, NC 28412  
910 341-7807  
910 341-5881 fax  
wilmingtonnc.gov  
Dial 711 TTY/Voice

## COMPREHENSIVE STORMWATER MANAGEMENT PERMIT

### HIGH DENSITY DEVELOPMENT

#### SECTION 1 – APPROVAL

Having reviewed the application and all supporting materials, the City of Wilmington has determined that the application is complete and the proposed development meets the requirements of the City of Wilmington’s Comprehensive Stormwater Ordinance.

PERMIT HOLDER: **City of Wilmington**  
PROJECT: **City of Wilmington Municipal Golf Course**  
ADDRESS: **311 Donald Ross Drive**  
PERMIT #: **2019004**  
DATE: **April 4th, 2019**

Therefore, the above referenced site is hereby approved and subject to all conditions set forth in Section 2 of this approval and all applicable provisions of the City of Wilmington Comprehensive Stormwater Management Ordinance.

This permit shall be effective from the date of issuance until April 4th, 2029 and shall be subject to the following specified conditions and limitations:

#### Section 2 - CONDITIONS

1. This approval is valid only for the stormwater management system as proposed on the approved stormwater management plans dated April 4th, 2019.
2. The project will be limited to the amount and type of built-upon area indicated in Section IV of the Stormwater Management Application Form submitted as part of the approved stormwater permit application package, and per the approved plans.
3. This permit shall become void unless the facilities are constructed in accordance with the approved stormwater management plans, specifications and supporting documentation, including information provided in the application and supplements.
4. The runoff from all built-upon area within any permitted drainage area must be directed into the permitted stormwater control system for that drainage area.



**Public Services**

Engineering  
212 Operations Center Drive  
Wilmington, NC 28412  
910 341-7807  
910 341-5881 fax  
wilmingtonnc.gov  
Dial 711 TTY/Voice

5. The permittee shall submit a revised stormwater management application packet to the City of Wilmington and shall have received approval prior to construction, for any modification to the approved plans, including, but not limited to, those listed below:
  - a. Any revision to any item shown on the approved plans, including the stormwater management measures, built-upon area, details, etc.
  - b. Redesign or addition to the approved amount of built-upon area or to the drainage area.
  - c. Further subdivision, acquisition, lease or sale of any part of the project area.
  - d. Filling in, altering, or piping of any vegetative conveyance shown on the approved plan.
  - e. Construction of any permitted future areas shown on the approved plans.
6. A copy of the approved plans and specifications shall be maintained on file by the Permittee.
7. During construction, erosion shall be kept to a minimum and any eroded areas of the system will be repaired immediately.
8. If the stormwater system was used as an Erosion Control device, it must be restored to design condition prior to operation as a stormwater treatment device, and prior to issuance of any certificate of occupancy for the project.
9. All areas must be maintained in a permanently stabilized condition. If vegetated, permanent seeding requirements must follow the guidelines established in the North Carolina Erosion and Sediment Control Planning and Design Manual unless an alternative is specified and approved by the City of Wilmington.
10. All applicable operation & maintenance agreements and easements pertaining to each stormwater treatment system shall be referenced on the final plat and recorded with the Register of Deeds upon final plat approval. If no plat is recorded for the site the operation and maintenance agreements and easements shall be recorded with the Register of Deeds so as to appear in the chain of title of all subsequent purchasers under generally accepted searching standards.
11. The stormwater management system shall be constructed in its entirety, vegetated and operational for its intended use prior to the construction of any built-upon surface unless prior approval is obtained. City Staff must be notified of any deviation prior to construction of the built-upon surface. Any deviation request shall include justification and must propose an alternative timeline or construction sequence. Notification shall not constitute approval. Any alternative timeline approved by City staff shall become an enforceable component of this permit.



**Public Services**

Engineering  
212 Operations Center Drive  
Wilmington, NC 28412  
910 341-7807  
910 341-5881 fax  
wilmingtonnc.gov  
Dial 711 TTY/Voice

12. The permittee shall at all times provide the operation and maintenance necessary to assure the permitted stormwater system functions at optimum efficiency. The approved Operation and Maintenance Agreement must be followed in its entirety and maintenance must occur at the scheduled intervals including, but not limited to:
  - a. Scheduled inspections (interval noted on the agreement).
  - b. Sediment removal.
  - c. Mowing and revegetation of slopes and the vegetated areas.
  - d. Maintenance of landscape plants, including those within the landscape buffer and on the vegetated shelf.
  - e. Immediate repair of eroded areas, especially slopes.
  - f. Debris removal and unclogging of outlet structure, orifice device, flow spreader, catch basins and/or piping.
  - g. Access to the outlet structure must be available at all times.
13. Records of inspection, maintenance and repair for the permitted stormwater system must be kept by the permittee for at least 5 years from the date of record and made available upon request to authorized personnel of the City of Wilmington. The records will indicate the date, activity, name of person performing the work and what actions were taken.
14. Upon completion of construction, before a Certificate of Occupancy shall be granted, and prior to operation or intended use of this permitted facility, the applicant shall submit to the City of Wilmington as-built plans for all stormwater management facilities. The plans shall show the final design specifications and the field location, type, depth, invert and planted vegetation of all measures, controls and devices, as-installed. A certification shall be submitted, along with all supporting documentation that specifies, under seal that the as-built stormwater measures, controls and devices are in compliance with the approved stormwater management plans. A final inspection by City of Wilmington personnel will be required prior to issuance of a certificate of occupancy or operation of the permitted facility.
15. This permit is not transferable except after application and approval by the City of Wilmington. In the event of a change of ownership, name change or change of address the permittee must submit a completed Name/Ownership Change form to the City of Wilmington at least 30 days prior to the change. It shall be signed by all applicable parties, and be accompanied by all required supporting documentation. Submittal of a complete application shall not be construed as an approved application. The application will be reviewed on its own merits by the City of Wilmington and may or may not be approved. The project must be in compliance with the terms of this permit in order for the transfer request to be considered. The permittee is responsible for compliance with all permit conditions until such time as the City of Wilmington approves the transfer request. Neither the sale of the project nor the conveyance of common area to a third party should be considered as an approved transfer of the permit.
16. Failure to abide by the conditions and limitations contained in this permit may subject the Permittee to enforcement action by the City of Wilmington, in accordance with Sections 18-52 and 18-53 and any other applicable section of the Land Development Code.



**Public Services**


Engineering  
212 Operations Center Drive  
Wilmington, NC 28412  
910 341-7807  
910 341-5881 fax  
wilmingtonnc.gov  
Dial 711 TTY/Voice

17. The City of Wilmington may notify the permittee when the permitted site does not meet one or more of the minimum requirements of the permit. Within the time frame specified in the notice, the permittee shall submit a written time schedule to the City of Wilmington for modifying the site to meet minimum requirements. The permittee shall provide copies of revised plans and certification in writing to the City of Wilmington that the changes have been made.
18. The issuance of this permit does not preclude the Permittee from complying with any and all statutes, rules, regulations, or ordinances, which may be imposed by other government agencies (local, state, and federal) having jurisdiction.
19. In the event that the facilities fail to perform satisfactorily, including the creation of nuisance conditions, the Permittee shall take immediate corrective action, including those as may be required by the City of Wilmington, such as the construction of additional or replacement stormwater management systems.
20. The permittee grants City of Wilmington Staff permission to enter the property during normal business hours for the purpose of inspecting all components of the permitted stormwater management facility.
21. The permit issued shall continue in force and effect until revoked or terminated by the City of Wilmington. The permit may be modified, revoked and reissued or terminated for cause. The filing of a request for a permit modification, revocation and re-issuance or termination does not stay any permit condition.
22. The approved stormwater management plans and all documentation submitted as part of the approved stormwater management permit application package for this project are incorporated by reference and are enforceable parts of the permit.
23. The permittee shall submit a renewal request with all required forms and documentation at least 180 days prior to the expiration date of this permit.
24. If any one or more of the conditions of this permit is found to be unenforceable or otherwise invalidated, all remaining conditions shall remain in full effect.

Stormwater Management Permit issued this the 4<sup>th</sup> day of April, 2019

A handwritten signature in blue ink, appearing to read 'S. Cheatham', is written over a horizontal line.

for Sterling Cheatham, City Manager  
City of Wilmington



Public Services  
Engineering  
414 Chestnut St, Suite 200  
Wilmington, NC 28401  
910 341-7807  
910 341-5881 fax  
wilmingtonnc.gov  
Dial 711 TTY/Voice



\* Unless otherwise  
Noted

**STORMWATER MANAGEMENT PERMIT APPLICATION FORM**  
(Form SWP 2.2)

**I. GENERAL INFORMATION**

1. Project Name (subdivision, facility, or establishment name - should be consistent with project name on plans, specifications, letters, operation and maintenance agreements, etc.):

City of Wilmington Municipal Golf Course

2. Location of Project (street address):

311 Donald Ross Drive

City: Wilmington County: New Hanover Zip: 28403

3. Directions to project (from nearest major intersection):

Site is located approx. 700 ft south of the Market Street (US Hwy 17) and New Centre Drive intersection, on the west side of New Centre Drive.

**II. PERMIT INFORMATION**

1. Specify the type of project (check one):  Low Density  High Density  
 Drains to an Offsite Stormwater System  Drainage Plan  Other

If the project drains to an Offsite System, list the Stormwater Permit Number(s):

City of Wilmington: \_\_\_\_\_ State – NCDENR/DWQ: \_\_\_\_\_

2. Is the project currently covered (whole or in part) by an existing City or State (NCDENR/DWQ) Stormwater Permit?  Yes  No

If yes, list all applicable Stormwater Permit Numbers:

City of Wilmington: \_\_\_\_\_ State – NCDENR/DWQ: \_\_\_\_\_

3. Additional Project Permit Requirements (check all applicable):

CAMA Major  Sedimentation/Erosion Control  
 NPDES Industrial Stormwater  404/401 Permit: Proposed Impacts: \_\_\_\_\_

If any of these permits have already been acquired please provide the Project Name, Project/Permit Number, issue date and the type of each permit:

\_\_\_\_\_

**III. CONTACT INFORMATION**

1. Print Applicant / Signing Official's name and title (specifically the developer, property owner, lessee, designated government official, individual, etc. who owns the project):

Applicant / Organization: City of Wilmington

Signing Official & Title: \_\_\_\_\_

- a. Contact information for Applicant / Signing Official:

Street Address: 102 North Third Street

City: Wilmington State: NC Zip: 28402

Phone: 910-341-7800 Fax: \_\_\_\_\_ Email: \_\_\_\_\_

Mailing Address (if different than physical address): \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

- b. Please check the appropriate box. The applicant listed above is:

- The property owner (Skip to item 3)  
 Lessee\* (Attach a copy of the lease agreement and complete items 2 and 2a below)  
 Purchaser\* (Attach a copy of the pending sales agreement and complete items 2 and 2a below)  
 Developer\* (Complete items 2 and 2a below.)

2. Print Property Owner's name and title below, if you are the lessee, purchaser, or developer. (This is the person who owns the property that the project is on.)

Property Owner / Organization: \_\_\_\_\_

Signing Official & Title: \_\_\_\_\_

- a. Contact information for Property Owner:

Street Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_ Email: \_\_\_\_\_

Mailing Address (if different than physical address): \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

3. (Optional) Print the name and title of another contact such as the project's construction supervisor or another person who can answer questions about the project:

Other Contact Person / Organization: \_\_\_\_\_

Signing Official & Title: \_\_\_\_\_

a. Contact information for person listed in item 3 above:

Street Address: \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_ Email: \_\_\_\_\_

Mailing Address (if different than physical address): \_\_\_\_\_

City: \_\_\_\_\_ State: \_\_\_\_\_ Zip: \_\_\_\_\_

**IV. PROJECT INFORMATION**

1. In the space provided below, briefly summarize how the stormwater runoff will be treated.

Stormwater runoff from the development will be treated in dry detention basin or surface runoff to the surrounding wooded areas.

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

- 2. Total Property Area: 200,940 square feet
- 3. Total Coastal Wetlands Area: 0 square feet
- 4. Total Surface Water Area: 0 square feet
- 5. Total Property Area (2) – Total Coastal Wetlands Area (3) – Total Surface Water Area (4) = Total Project Area: 200,940 square feet.
- 6. Existing Impervious Surface within Property Area: 72,346 square feet
- 7. Existing Impervious Surface to be Removed/Demolished: 15,118 square feet
- 8. Existing Impervious Surface to Remain: 57,228 square feet
- 9. Total Onsite (within property boundary) Newly Constructed Impervious Surface (*in square feet*):

|  |               |
|--|---------------|
| Buildings/Lots   | 6,914         |
| Impervious Pavement                                      | 12,723        |
| Pervious Pavement (adj. total, with 0% credit applied)   | 0             |
| Impervious Sidewalks                                     | 3,893         |
| Pervious Sidewalks (adj. total, with 0% credit applied)  | 0             |
| Other (describe) Concrete                                | 1,211         |
| Future Development                                       | 0             |
| <b>Total Onsite Newly Constructed Impervious Surface</b> | <b>24,741</b> |

10. Total Onsite Impervious Surface  
 (Existing Impervious Surface to remain + Onsite Newly Constructed Impervious Surface) = 81,969 square feet

11. Project percent of impervious area: (Total Onsite Impervious Surface / Total Project Area) x100 = 41 %

12. Total Offsite Newly Constructed Impervious Area (improvements made outside of property boundary, in square feet):

|   |          |
|---|----------|
| Impervious Pavement                                       | 0        |
| Pervious Pavement (adj. total, with % credit applied)     | 0        |
| Impervious Sidewalks                                      |          |
| Pervious Sidewalks (adj. total, with % credit applied)    | 0        |
| Other (describe)  | 0        |
| <b>Total Offsite Newly Constructed Impervious Surface</b> | <b>0</b> |

13. Total Newly Constructed Impervious Surface  
 (Total Onsite + Offsite Newly Constructed Impervious Surface) = 24741 square feet

14. Complete the following information for each Stormwater BMP drainage area. If there are more than three drainage areas in the project, attach an additional sheet with the information for each area provided in the same format as below. Low Density projects may omit this section and skip to Section V.

| Basin Information                  | Dry Detention Basin<br>BMP # 1 | BMP #    | BMP #    |
|------------------------------------|--------------------------------|----------|----------|
| Receiving Stream Name              | UT Hewletts Creek              |          |          |
| Receiving Stream Index Number      | 18-87-26                       |          |          |
| Stream Classification              | SA; HQW                        |          |          |
| Total Drainage Area (sf)           | 71366                          | 0        | 0        |
| On-Site Drainage Area (sf)         | 71366                          |          |          |
| Off-Site Drainage Area (sf)        | 0                              |          |          |
| <b>Total Impervious Area (sf)</b>  | <b>33414</b>                   | <b>0</b> | <b>0</b> |
| Buildings/Lots (sf)                | 7350                           |          |          |
| Impervious Pavement (sf)           | 23984                          |          |          |
| Pervious Pavement, % credit (sf)   | 0                              |          |          |
| Impervious Sidewalks (sf)          | 2080                           |          |          |
| Pervious Sidewalks, % credit (sf)  | 0                              |          |          |
| Other (sf)                         | 0                              |          |          |
| Future Development (sf)            | 0                              |          |          |
| Existing Impervious to remain (sf) | 0                              |          |          |
| Offsite (sf)                       | 0                              |          |          |
| Percent Impervious Area (%)        | 46.8%                          |          |          |

15. How was the off-site impervious area listed above determined? Provide documentation:

---



---



## V. SUBMITTAL REQUIREMENTS

1. Supplemental and Operation & Maintenance Forms - One applicable City of Wilmington Stormwater BMP supplement form and checklist must be submitted for **each** BMP specified for this project. One applicable proposed operation and maintenance (O&M) form must be submitted for **each type** of stormwater BMP. Once approved, the operation and maintenance forms must be referenced on the final plat and recorded with the register of deeds office.
2. Deed Restrictions and Restrictive Covenants - For all subdivisions, outparcels, and future development, the appropriate property restrictions and protective covenants are required to be recorded prior to the sale of any lot. Due to variability in lot sizes or the proposed BUA allocations, a table listing each lot number, lot size, and the allowable built-upon area must be provided as an attachment to the completed and notarized deed restriction form. The appropriate deed restrictions and protective covenants forms can be downloaded at the link listed in section V (3). Download the latest versions for each submittal.

In instances where the applicant is different than the property owner, it is the responsibility of the property owner to sign the deed restrictions and protective covenants form while the applicant is responsible for ensuring that the deed restrictions are recorded.

**By the notarized signature(s) below, the permit holder(s) certify that the recorded property restrictions and protective covenants for this project, if required, shall include all the items required in the permit and listed on the forms available on the website, that the covenants will be binding on all parties and persons claiming under them, that they will run with the land, that the required covenants cannot be changed or deleted without concurrence from the City of Wilmington, and that they will be recorded prior to the sale of any lot.**

3. Only complete application packages will be accepted and reviewed by the City. A complete package includes all of the items listed on the City Engineering Plan Review Checklist, including the fee. Copies of the Engineering Plan Review Checklist, all Forms, Deed Restrictions as well as detailed instructions on how to complete this application form may be downloaded from:

<http://www.wilmingtonnc.gov/PublicServices/Engineering/PlanReview/StormwaterPermits.aspx>

The complete application package should be submitted to the following address:

City of Wilmington – Engineering  
Plan Review Section  
414 Chestnut Street, Suite 200  
Wilmington, NC 28402

**VI. CONSULTANT INFORMATION AND AUTHORIZATION**

1. Applicant: Complete this section if you wish to designate authority to another individual and/or firm (such as a consulting engineer and /or firm) so that they may provide information on your behalf for this project (such as addressing requests for additional information).

Consulting Engineer: J. Branch Smith, PE

Consulting Firm: Paramounte Engineering, Inc.

a. Contact information for consultant listed above:

Mailing Address: 122 Cinema Drive

City: Wilmington State: NC Zip: 28403


Phone: 910-791-6707 Fax: 910-791-6760 Email: bsmith@paramounte-eng.com

**VII. PROPERTY OWNER AUTHORIZATION** (If Section III(2) has been filled out, complete this section)

I, *(print or type name of person listed in Contact Information, item 2)* \_\_\_\_\_, certify that I own the property identified in this permit application, and thus give permission to *(print or type name of person listed in Contact Information, item 1)* \_\_\_\_\_ with *(print or type name of organization listed in Contact Information, item 1)* \_\_\_\_\_ to develop the project as currently proposed. A copy of the lease agreement or pending property sales contract has been provided with the submittal, which indicates the party responsible for the operation and maintenance of the stormwater system.

As the legal property owner I acknowledge, understand, and agree by my signature below, that if my designated agent (*entity listed in Contact Information, item 1*) dissolves their company and/or cancels or defaults on their lease agreement, or pending sale, responsibility for compliance with the City of Wilmington Stormwater Permit reverts back to me, the property owner. As the property owner, it is my responsibility to notify the City of Wilmington immediately and submit a completed Name/Ownership Change Form within 30 days; otherwise I will be operating a stormwater treatment facility without a valid permit. I understand that the operation of a stormwater treatment facility without a valid permit is a violation of the City of Wilmington Municipal Code of Ordinances and may result in appropriate enforcement including the assessment of civil penalties.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_




I, \_\_\_\_\_, a Notary Public for the State of \_\_\_\_\_, County of \_\_\_\_\_, do hereby certify that \_\_\_\_\_ personally appeared before me this day of \_\_\_\_\_, \_\_\_\_\_, and acknowledge the due execution of the application for a stormwater permit. Witness my hand and official seal,

My commission expires: \_\_\_\_\_

**VIII. APPLICANT'S CERTIFICATION**

I, *(print or type name of person listed in Contact Information, item 1)* \_\_\_\_\_ certify that the information included on this permit application form is, to the best of my knowledge, correct and that the project will be constructed in conformance with the approved plans, that the required deed restrictions and protective covenants will be recorded, and that the proposed project complies with the requirements of the applicable stormwater rules under.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_



I, \_\_\_\_\_, a Notary Public for the State of \_\_\_\_\_, County of \_\_\_\_\_, do hereby certify that \_\_\_\_\_ personally appeared before me this day of \_\_\_\_\_, \_\_\_\_\_, and acknowledge the due execution of the application for a stormwater permit. Witness my hand and official seal,

\_\_\_\_\_  
My commission expires: \_\_\_\_\_

# Operation & Maintenance Agreement

**Project Name:** City of Wilmington Municipal Golf Course

**Project Location:** 311 Donald Ross Drive, Wilmington, NC 28409

## Cover Page

Maintenance records shall be kept on the following BMP(s). This maintenance record shall be kept in a log in a known set location. Any deficient BMP elements noted in the inspection will be corrected, repaired, or replaced **immediately**. These deficiencies can affect the integrity of structures, safety of the public, and the pollutant removal efficiency of the BMP(s).

The BMP(s) on this project include (check all that apply & corresponding O&M tables will be added automatically):

|                              |           |    |              |                            |
|------------------------------|-----------|----|--------------|----------------------------|
| Bioretention Cell            | Quantity: |    | Location(s): |                            |
| Dry Detention Basin          | Quantity: | 1  | Location(s): | Near Maintenance Buildings |
| Grassed Swale                | Quantity: |    | Location(s): |                            |
| Green Roof                   | Quantity: |    | Location(s): |                            |
| Infiltration Basin           | Quantity: |    | Location(s): |                            |
| Infiltration Trench          | Quantity: |    | Location(s): |                            |
| Level Spreader/VFS           | Quantity: |    | Location(s): |                            |
| Permeable Pavement           | Quantity: |    | Location(s): |                            |
| Proprietary System           | Quantity: |    | Location(s): |                            |
| Rainwater Harvesting         | Quantity: |    | Location(s): |                            |
| Sand Filter                  | Quantity: |    | Location(s): |                            |
| Stormwater Wetland           | Quantity: |    | Location(s): |                            |
| Wet Detention Basin          | Quantity: | 0  | Location(s): |                            |
| Disconnected Impervious Area | Present:  | No | Location(s): |                            |
| User Defined BMP             | Present:  | No | Location(s): |                            |

I acknowledge and agree by my signature below that I am responsible for the performance of the maintenance procedures listed for each BMP above, and attached O&M tables. I agree to notify NCDENR of any problems with the system or prior to any changes to the system or responsible party.


\* Responsible Party:

|                       |
|-----------------------|
| Title & Organization: |
| Street address:       |
| City, state, zip:     |
| Phone number(s):      |
| Email:                |

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

I, \_\_\_\_\_, a Notary Public for the State of \_\_\_\_\_  
 County of \_\_\_\_\_, do hereby certify that \_\_\_\_\_  
 personally appeared before me this \_\_\_\_\_ day of \_\_\_\_\_ and  
 acknowledge the due execution of the Operations and Maintenance Agreement .

Witness my hand and official seal, \_\_\_\_\_.





Important maintenance procedures:

- The drainage area will be managed to reduce the sediment load to the dry extended detention basin.
- Immediately after the dry extended detention basin is established, the vegetation will be watered twice weekly if needed until the plants become established (commonly six weeks).
- No portion of the dry extended detention pond will be fertilized after the first initial fertilization that is required to establish the vegetation.
- The vegetation in and around the basin will be maintained at a height of approximately six inches.
- If cracks, seepage, or woody vegetation is present, consult a dam safety expert for a dam inspection.

The measuring device used to determine the sediment elevation shall be such that it will give an accurate depth reading and not readily penetrate into accumulated sediments.

After the dry detention basin is established, it will be inspected **quarterly**. Inspection activities shall be performed as follows and any problems identified will be remediated immediately per the table below.

| <b>BMP element:</b>             | <b>Potential problem:</b>                                      | <b>How to remediate the problem:</b>  |
|---------------------------------|--|---|
| <b>The entire BMP</b>           | Trash/debris is present.                                       | Remove the trash/debris.  |
| <b>The perimeter of the BMP</b> | Areas of bare soil and/or erosive gullies have formed.         | Regrade the soil if necessary to remove the gully, and then plant a ground cover and water until it is established. Provide lime and a one-time fertilizer application. |
|                                 | Vegetation is too short or too long.                           | Maintain vegetation at a height of approximately six inches.  |
| <b>The inlet device</b>         | The pipe is clogged.   | Unclog the pipe. Dispose of the sediment off-site.  |
|                                 | The pipe is cracked or otherwise damaged.                      | Replace the pipe.   |
|                                 | Erosion is occurring in the swale.                             | Regrade the swale if necessary to smooth it over and provide erosion control devices such as reinforced turf matting or riprap to avoid future problems with erosion.   |
|                                 | Stone verge is clogged or covered in sediment (if applicable). | Remove sediment and replace with clean stone.   |
| <b>The forebay</b>              | Trash/debris is present.                                       | Remove the trash/debris.  |
|                                 | Erosion has occurred or riprap is displaced.                   | Provide additional erosion protection such as reinforced turf matting or riprap if needed to prevent future erosion problems.   |
|                                 | Weeds are present.   | Remove the weeds, preferably by hand. If pesticides are used, wipe them on the plants rather than spraying.   |

**Dry Detention Pond Maintenance Requirements (continued)**

| <b>BMP element:</b>            | <b>Potential problem:</b>   | <b>How to remediate the problem:</b>   |
|--------------------------------|---|--|
| <b>The main treatment area</b> | Sediment has accumulated and reduced the depth to 75% of the original design depth (per pond design data sheet) | Search for the source of the sediment and remedy the problem if possible. Remove the sediment and dispose of it in a location where it will not cause impacts to streams or the BMP. Revegetate disturbed areas immediately with sod (preferred) or seed protected with securely staked erosion mat. |
|                                | Water is standing more than 5 days after a storm event.   | Check outlet structure for clogging. If it is a design issue, consult an appropriate professional.   |
|                                | Weeds and noxious plants are growing in the main treatment area.  | Remove the plants by hand or by wiping them with pesticide (do not spray).   |
| <b>The embankment</b>          | Shrubs or trees have started to grow on the embankment.   | Remove shrubs or trees immediately.  |
|                                | Grass cover is unhealthy or eroding.  | Restore the health of the grass cover – consult a professional if necessary.   |
|                                | Signs of seepage on the downstream face.  | Consult a professional.  |
|                                | Evidence of muskrat or beaver activity is present.  | Use traps to remove muskrats and consult a professional to remove beavers.   |
|                                | An annual inspection by an appropriate professional shows that the embankment needs repair.                     | Make all needed repairs.   |
| <b>The outlet device</b>       | Clogging has occurred.  | Clean out the outlet device. Dispose of the sediment off-site.   |
|                                | The outlet device is damaged  | Repair or replace the outlet device.   |
| <b>The receiving water</b>     | Erosion or other signs of damage have occurred at the outlet.   | Contact the local NC Department of Environment and Natural Resources Regional Office.  |

# Dry Detention Pond Design Summary

## Dry Pond Diagram

| DRY POND ID      |     | FOREBAY              |         | MAIN POND            |      |
|------------------|-----|----------------------|---------|----------------------|------|
| Beside Cart Barn |     | Temporary Pool El:   | NA      | Temporary Pool El:   | 38.9 |
| Pretreatment     | Yes | Clean Out Depth:     | #VALUE! | Clean Out Depth:     | 3.9  |
| Has Veg. Filter  | Yes | Sediment Storage El: |         | Sediment Storage El: | 35   |
|                  |     | Bottom Elevation:    |         | Bottom Elevation:    | 34   |